

CONSENT MONITORING REPORT



Your Community Partner

Consent Name	Maramarua Wastewater Treatment System
Consent No.	101961
Year	2007-08
Date	31 October 2008
File No.	55 06 22M

District Office
15 Galileo St, Private Bag 544
Ngaruawahia New Zealand
Ph 07 824 8633
Fax 07 824 8091
Call Free 0800 492 452
www.waikatodistrict.govt.nz

Area Offices
Huntly 07 828 7551
Raglan 07 825 8129

REPORT/COMMENTS

Maramarua Wastewater Treatment System

The Waikato District Council holds resource consent to discharge up to 6 cubic metres of treated sewage effluent per day to ground from the Maramarua wastewater treatment system. The consent was issued on 2nd March 2000 and has an expiry date of 1st December 2014.

The treatment plant has performed adequately in the reporting period however the discharge volume has been exceeded several times due to increased wet weather inflow.

Investigations point to this being at the receiving pump station and primary septic tanks that date from the original Ministry of Works system.

A project is scheduled for the 2008-2009 period to replace the septic tanks, remediate the pumping station and seal them from groundwater inflow.

.....
H Cameron
Plants Engineer

.....
R J Bax
Community Assets Group Manager