

# CONSENT MONITORING REPORT



Your Community Partner

Consent Name	Maramarua Wastewater Treatment System
Consent No.	101961
Year	1 July 2011 – 30 June 2012
Date	28 September 2012
File No.	55 06 22M / USV03

**District Office**  
15 Galileo St, Private Bag 544  
Ngaruawahia New Zealand  
Ph 07 824 8633  
Fax 07 824 8091  
Call Free 0800 492 452  
[www.waikatodistrict.govt.nz](http://www.waikatodistrict.govt.nz)

**Area Offices**  
Huntly 07 828 7551  
Raglan 07 825 8129

## REPORT/COMMENTS

### Maramarua Wastewater Treatment System 1 July 2011 to 30 June 2012

The Waikato District Council holds a resource consent to discharge up to 6 cubic metres of treated sewage effluent per day to ground from the Maramarua wastewater treatment system. The consent was issued on 2 March 2000 and has an expiry date of 1 December 2014.

Flows from the plant have exceeded the consent allowance on 52 days during the year.

The treatment process has been improved by the addition of coarse filters between the recirculation tank and sand filter.

Survey and some remedial work to reduce infiltration has been partially successful. This is a very small community of some 8 houses and also a small consent limit of 6 cubic meters per day. The ground water table is high during winter months.

.....  
**P Seward**  
**TREATMENT PLANTS ENGINEER**

.....  
**R J Bax**  
**GENERAL MANAGER**  
**WATER & FACILITIES**