


940355 Te Kauwhata Wastewater sewage treatment discharge 2009-2010

This consent authorises the Consent Holder to: discharge 1080 cubic metres per day of treated wastewater via a rock seepage bed to Lake Waikare, at a site at or about NZMS 260 S13 009 195

	Conditions	Comply Yes/No	Comments
*	This consent authorises the Consent Holder to: discharge 1080 cubic metres per day of treated wastewater	No	<p>Non Compliant.</p> <p>Regular Non compliance with this condition especially during winter months. Inflow data demonstrates large portion of outflow contribution from rainfall or possibly infiltration to wetland. During heavy wet weather storm events outflow well beyond the normal flow range of the treatment plant occurred.</p> <p>The median Maximum monthly out flow was 1051 cubic metres per day over the total reporting period.</p> <p>The median Average monthly outflow was 570 cubic metres per day over the total reporting period.</p> <p>The 90th percentile Maximum monthly flow was 1534 m3/day.</p> <p>Maximum recorded daily total flow was 2467 m3/day on 26 June 2010. The Environment Waikato rainfall record at the Mercer Control Structure shows significant rain at this time.</p> <div data-bbox="1160 922 2159 1390" style="text-align: center;"> <p>Te Kauwhata WWTP Inflow / Outflow Daily Average</p> <p>Legend: - Average Daily In Flow (Blue line with diamonds) - Average Daily Out Flow (Green line with squares) - Maximum Daily In Flow (Magenta line with squares) - Maximum Daily Out Flow (Purple line with triangles) - Discharge Limit (Dashed red line)</p> </div>

	Conditions	Comply Yes/No	Comments
1	The treatment system comprising a two-oxidation pond system shall be modified to include a tertiary wetland and rock seepage bed, in accordance with the “Assessment of Environmental Effects – Te Kauwhata Oxidation Ponds”, prepared for Waikato District Council by Beca Steven, 28 June 1994 and from further information provided by Beca Steven. The modified plant shall be operated and maintained to maximise the treatment efficiency and to the satisfaction of the Waikato Regional Council.	Yes	<p>The treatment upgrade was completed as proposed in resource consent application documents. This was completed in 1995.</p> <p>An upgrade was completed in May 2007 to install pre-screening, and suspended media Aquamats in both ponds with bottom deployed fine bubble aeration.</p> 
2	The consent holder shall retain appropriately experienced personnel to operate the treatment system.	Yes	The treatment plant is managed and operated by appropriately trained and experienced engineers and operators.
3	The consent holder shall forward for approval to the Waikato Regional Council copies of the proposed wetland design along with hydraulic flow and loading design criteria, proposed planting details as well as the planned timetable for installation, such material shall be provided prior to the commencement of site work.	Yes	Detailed design approved by Environment Waikato and implemented by Waikato District Council.
4	The consent holder shall meet with the Richmond Meat works to establish clear criteria for effluent discharge that may be passed to the treatment system covered by this consent. Such criteria shall then be used to form the basis of a trade waste discharge agreement with this company that enables the consent holder to more effectively control the final effluent quality leaving its own treatment system.	n/a	There is currently no meat processing plant operating from the site of the old Richmond Plant. The discharge line from the site is still monitored and no flow has been recorded.
5	The consent holder shall erect signs on the boundary of the site to warn the public that the area is used for waste treatment.	Yes	Warning signs are located on the two access gates to the treatment area.
6	The consent holder shall retain a suitably qualified and experienced person to compile an operations and management manual for the treatment and discharge systems. This manual will detail how the systems are to be operated to ensure that effluent treatment is maximised at all times. As a minimum the manual shall address the following matters:	Yes	A new operations manual was created as part of the upgrade and provided to Environment Waikato in June 2007.

	Conditions	Comply Yes/No	Comments
	<p>(a) A description of the entire treatment system facility, comprising a two-pond system plus the proposed tertiary wetland and final rock seepage component.</p> <p>(b) Routine maintenance procedures to be undertaken.</p> <p>(c) Management procedures specific to the land based discharge system including responses to wind speed and direction, rainfall and frost conditions on the site.</p> <p>(d) Development, management and maintenance of the wetland area including plant infrastructure and buffer zones.</p> <p>(e) Management of the treatment system to maximise removal of nitrogen in the land based discharge area.</p> <p>(f) Contingency measures in place to deal with unusual events.</p> <p>(g) Other actions necessary to comply with the provisions of this resource consent.</p> <p>(h) Procedures for improving and/or reviewing the management plan.</p>	<p>Yes</p> <p>Yes</p> <p>Yes</p> <p>Yes</p> <p>Yes</p> <p>Yes</p> <p>Yes</p> <p>Yes</p>	<p>A description is provided in the current manual.</p> <p>Documented maintenance visits and inspections done. There were 33 in 2010. The treatment system is managed and operated in accordance with a management plan.</p> <p>Council's Annual Plan requires regular inspections. These are documented and filed.</p> <p>Wetlands are in operation Nitrogen removal is being achieved Staff are on call after normal business hours and at weekends – contingency procedure is in manual.</p> <p>Telemetry monitors multiple plant elements and are alarmed to the on-call phone</p>
7	<p>The manual shall be written to a suitable standard and shall be forwarded to the Waikato Regional Council for its written approval prior to 1st November 1998.</p> <p>The consent holder shall update the manual at least once in every two (2) years that this resource consent is current and also within two (2) months of the completion of trade waste discharge agreements with the Richmond Meat works.</p> <p>Copy of the updated manual shall be forwarded to the Waikato Regional Council within one (1) month of any update being completed.</p>	Yes	<p>The manual has not been updated since June 2007.</p> <p>No operational changes or additions have been undertaken. A review of the procedures and manual will be undertaken to meet the requirements of the new consent.</p>
8	The treatment and disposal systems shall be operated, maintained and managed in accordance with the operation and management manual.	Yes	Maintenance visits and monthly sample collection are documented on inspection sheets.
9	The activities authorised by this resource consent shall be undertaken in such a manner that they do not produce an objectionable odour at or beyond the outer boundary of the land to which this resource consent relates. For the purpose of this	Yes	There have been no complaints received by the Council concerning objectionable odour during the 2009-2010 year. Regular inspections have not detected any odours from the sewage treatment system that could be considered objectionable to neighbouring properties.

	Conditions	Comply Yes/No	Comments
	<p>condition, the Waikato Regional Council will consider an odour that is objectionable or offensive to have occurred if any appropriately experienced officer of the Waikato Regional Council deems it so having regard to:</p> <ul style="list-style-type: none"> (a) The frequency, intensity, duration, amount and location of the effect(s) of the offensiveness of an odour; and/or (b) A written declaration from no less than three individuals that the effect odour was objectionable or offensive. That declaration shall include the individuals' names; and (c) Addresses, the date and time that the nuisance event occurred and when it was detected. Where a declaration is made following a number of discharge events having objectionable or offensive effects, that declaration shall provide details of the frequency, intensity, duration and location of those events. The individuals shall also state the circumstances that led to the declaration (for example, called upon by another individual, detected from a distance). The declaration shall be signed and dated; and/or (d) Relevant written advice or a report from an Environmental Health Officer of a territorial authority or Health Authority. 		
10	<p>Should an event occur which results in an objectionable or offensive odour, the consent holder shall, within 5 days of being advised of this event by the Waikato Regional Council, provide a written report to the Waikato Regional Council specifying:</p> <ul style="list-style-type: none"> (a) The cause or likely cause of the event and any factors that influenced its severity. (b) The nature and timing of any measures implemented by the consent holder to avoid, remedy or mitigate any adverse effects. <p>The steps to be taken in the future to prevent a recurrence of similar events.</p>	Yes	The Waikato District Council Stakeholder Relationship Customer Delivery Team has received no complaints regarding the operation of the plant or discharge of treated effluent from the site during 2009/2010.
11	<p>The consent holder shall retain an appropriately experienced person to develop an ongoing treatment system discharge quality-monitoring programme. As a minimum the monitoring programme shall include but not restricted to the following:</p>	Yes	<p>The monitoring programme is detailed in the approved operations manual and schedule supervised by WDC Plant Engineer.</p> <p>The monitoring programme is carried out according to the schedule.</p>

	Conditions	Comply Yes/No	Comments																																																																	
	<p>(a) cBOD₅.</p> <p>(b) Suspended Solids (SS).</p> <p>(c) TKN.</p> <p>(d) Nitrate Nitrogen.</p> <p>(e) Ammonia Nitrogen.</p> <p>(f) Dissolved Reactive Phosphorus (DRP).</p> <p>(g) Faecal Coliforms.</p> <p>(h) Daily volume of effluent.</p> <p>(i) Reporting procedures and dates.</p> <p>(j) Monitoring to determine compliance with the conditions of this resource consent.</p> <p>(k) Any other monitoring considered necessary by the programme developer.</p> <p>(l) Measurement of the effluent shall be on a monthly basis with samples taken both before and after the wetland for the first 5 years of this consent and thereafter only taken after the wetland.</p> <p>(m) Nitrate levels in groundwater at the boundary of the wetland area.</p>		<p>The results indicate the treatment system has generally improved. The treatment system continued achieving an exceptionally high level of suspended solids control and having no more than a minor effect on receiving waters.</p> <p>The data shows the wetlands continue to contribute a significant improvement to the overall treatment performance.</p> <p>Wetland Outlet Median Values</p> <table border="1" data-bbox="1149 454 2004 734"> <thead> <tr> <th></th> <th>Med 06-07</th> <th>Med 07-08</th> <th>Med 08-09</th> <th>Med 09-10</th> </tr> </thead> <tbody> <tr> <td>(a) cBOD₅</td> <td>3.5</td> <td>1.95</td> <td>2.1</td> <td>2.3</td> </tr> <tr> <td>(b) SS</td> <td>11</td> <td>5.9</td> <td>6.6</td> <td>5.9</td> </tr> <tr> <td>(c) TKN</td> <td>5.5</td> <td>3.5</td> <td>2.45</td> <td>2.1</td> </tr> <tr> <td>(d) NO₃-N</td> <td>0.12</td> <td>0.06</td> <td>0.16</td> <td>0.03</td> </tr> <tr> <td>(e) NH₄-N</td> <td>1.8</td> <td>1.3</td> <td>0.62</td> <td>0.51</td> </tr> <tr> <td>(f) DRP</td> <td>2.85</td> <td>5.75</td> <td>2.95</td> <td>3.4</td> </tr> <tr> <td>(g) FC</td> <td>950</td> <td>185</td> <td>150</td> <td>260</td> </tr> <tr> <td>(h) Avg m³/day</td> <td>411</td> <td>427</td> <td>492</td> <td>570</td> </tr> </tbody> </table> <p>The nitrate NO₃-N levels recorded at the monitoring bores are negligible</p> <table border="1" data-bbox="1149 837 2072 957"> <thead> <tr> <th>Nitrate NO₃-N</th> <th>14-Jul-09</th> <th>28-Oct-09</th> <th>20-Jan-10</th> <th>20-Apr-10</th> </tr> </thead> <tbody> <tr> <td>BH 1</td> <td>0.012</td> <td>0.015</td> <td>0.017</td> <td>0.056</td> </tr> <tr> <td>BH 2</td> <td>0.0046</td> <td>0.0094</td> <td>0.047</td> <td>0.056</td> </tr> <tr> <td>BH3</td> <td>0.056</td> <td>0.022</td> <td>0.028</td> <td>0.0125</td> </tr> </tbody> </table>		Med 06-07	Med 07-08	Med 08-09	Med 09-10	(a) cBOD ₅	3.5	1.95	2.1	2.3	(b) SS	11	5.9	6.6	5.9	(c) TKN	5.5	3.5	2.45	2.1	(d) NO ₃ -N	0.12	0.06	0.16	0.03	(e) NH ₄ -N	1.8	1.3	0.62	0.51	(f) DRP	2.85	5.75	2.95	3.4	(g) FC	950	185	150	260	(h) Avg m ³ /day	411	427	492	570	Nitrate NO ₃ -N	14-Jul-09	28-Oct-09	20-Jan-10	20-Apr-10	BH 1	0.012	0.015	0.017	0.056	BH 2	0.0046	0.0094	0.047	0.056	BH3	0.056	0.022	0.028	0.0125
	Med 06-07	Med 07-08	Med 08-09	Med 09-10																																																																
(a) cBOD ₅	3.5	1.95	2.1	2.3																																																																
(b) SS	11	5.9	6.6	5.9																																																																
(c) TKN	5.5	3.5	2.45	2.1																																																																
(d) NO ₃ -N	0.12	0.06	0.16	0.03																																																																
(e) NH ₄ -N	1.8	1.3	0.62	0.51																																																																
(f) DRP	2.85	5.75	2.95	3.4																																																																
(g) FC	950	185	150	260																																																																
(h) Avg m ³ /day	411	427	492	570																																																																
Nitrate NO ₃ -N	14-Jul-09	28-Oct-09	20-Jan-10	20-Apr-10																																																																
BH 1	0.012	0.015	0.017	0.056																																																																
BH 2	0.0046	0.0094	0.047	0.056																																																																
BH3	0.056	0.022	0.028	0.0125																																																																
12	The programme shall be developed to the satisfaction of the Waikato Regional Council, and shall be submitted to the Regional Council within six (6) months from the date of granting this consent.	Yes																																																																		
13	<p>The consent holder shall retain an appropriately experienced person to develop an ongoing receiving water quality-monitoring programme. This programme shall address the effects of the discharge on receiving water quality. The objectives of this monitoring programme shall incorporate the following but shall not be restricted to:</p> <p>(a) To monitor parameters as set down under condition 11 of</p>	Yes	<p>As part of the application for a new consent this has been addressed.</p> <p>Sample records for the four quarters are available. Samples are taken from four points within 100m of the discharge outlet stream entering the lake.</p>																																																																	

	Conditions	Comply Yes/No	Comments																																																							
	<p>this consent.</p> <p>(c) To measure the receiving water quality on a quarterly basis with samples taken within 100 metres of the outfall discharge point and within likely flow paths from the discharge.</p> <p>(c) To arrange an annual meeting between the Fish and Game Council, Department of Conservation and the Waikato Regional Council, to discuss the results of this monitoring, any trends emerging and respective treatment system upgrades that are planned, such meetings shall be within one month of the latest sampling and monitoring reports that have been circulated.</p>	<p>Yes</p> <p>No</p>	<p>Lake Waikare Average of 4 sample sites results</p> <table border="1" data-bbox="1149 263 2027 606"> <thead> <tr> <th></th> <th>14-Jun-09</th> <th>28-Oct-09</th> <th>20-Jan-10</th> <th>20-Apr-10</th> </tr> </thead> <tbody> <tr> <td>cBOD5</td> <td>3.1</td> <td>5.2</td> <td>7.6</td> <td>4.6</td> </tr> <tr> <td>SS</td> <td>94</td> <td>59</td> <td>77</td> <td>65</td> </tr> <tr> <td>TKN</td> <td>1.4</td> <td>1.7</td> <td>4.2</td> <td>2</td> </tr> <tr> <td>NO3-N</td> <td><1</td> <td><0.002</td> <td><0.002</td> <td><0.002</td> </tr> <tr> <td>NH4-N</td> <td><0.1</td> <td><0.1</td> <td><0.1</td> <td><0.01</td> </tr> <tr> <td>TP</td> <td>0.19</td> <td>0.15</td> <td>0.2</td> <td>0.14</td> </tr> <tr> <td>FC</td> <td>208</td> <td>29</td> <td>72</td> <td>135</td> </tr> <tr> <td>pH</td> <td>7.6</td> <td>8.6</td> <td>9.6</td> <td>8.6</td> </tr> <tr> <td>Cond (uS)</td> <td>180</td> <td>150</td> <td>172</td> <td>153</td> </tr> <tr> <td>Temp</td> <td>6.9</td> <td>17.4</td> <td>22.85</td> <td>17.6</td> </tr> </tbody> </table> <p>The results indicate little influence from the WWTP discharge.</p> <p>An annual meeting has not been conducted, however the General Manager Water & Facilities and the consultants assisting with the resource consent renewals met with both organisations in August 2010 to discuss the plant operations.</p>		14-Jun-09	28-Oct-09	20-Jan-10	20-Apr-10	cBOD5	3.1	5.2	7.6	4.6	SS	94	59	77	65	TKN	1.4	1.7	4.2	2	NO3-N	<1	<0.002	<0.002	<0.002	NH4-N	<0.1	<0.1	<0.1	<0.01	TP	0.19	0.15	0.2	0.14	FC	208	29	72	135	pH	7.6	8.6	9.6	8.6	Cond (uS)	180	150	172	153	Temp	6.9	17.4	22.85	17.6
	14-Jun-09	28-Oct-09	20-Jan-10	20-Apr-10																																																						
cBOD5	3.1	5.2	7.6	4.6																																																						
SS	94	59	77	65																																																						
TKN	1.4	1.7	4.2	2																																																						
NO3-N	<1	<0.002	<0.002	<0.002																																																						
NH4-N	<0.1	<0.1	<0.1	<0.01																																																						
TP	0.19	0.15	0.2	0.14																																																						
FC	208	29	72	135																																																						
pH	7.6	8.6	9.6	8.6																																																						
Cond (uS)	180	150	172	153																																																						
Temp	6.9	17.4	22.85	17.6																																																						
14	<p>The consent holder shall compile an annual monitoring report for the year ending 1998 and for each year that this resource consent is current. As a minimum the report shall:</p> <p>(a) Include all the data collected as required under conditions 11 and 17 of this resource consent.</p> <p>(b) Critically analyse the information collected, in terms of compliance and actual or potential effects.</p> <p>(c) Compare data with previously collected results and identify and comment on any emerging trends.</p> <p>(d) Make recommendations on alterations or additions to the monitoring programme, if required.</p> <p>(e) Any other issue considered important by the consent holder.</p>	Yes	<p>Data is recorded for Environment Waikato. All the recorded data is supplied with this annual report in complete form.</p> <p>Report for period July 2009 to June 2010 attached</p>																																																							

	Conditions	Comply Yes/No	Comments																																													
15	The report shall be to a standard acceptable to the Waikato Regional Council and shall be forwarded to the Waikato Regional Council by March 31 st for each year that this resource consent is current.	Yes	A change in consent condition was granted through s127 change to 30 September each year.																																													
16	The consent holder shall give effect to the mitigation measures agreed between the Auckland/Waikato Fish and Game Council in collaboration with the Department of Conservation (Waikato Region) and specifically for the consent holder to provide stock proof fencing on Department of Conservation land along the margin of Lake Waikare as shown on a marked up map which accompanied the agreement with the Fish and Game Council.	Yes	There is stock proof fencing surrounding the site. Within to the site stock are only occasionally permitted, electric temporary fencing is then used to protect the lake margin.																																													
17	<p>When the consent holder decides that leachate from the adjacent Te Kauwhata landfill is to be passed into the treatment system covered by this consent then the following actions shall be undertaken prior to such decision being given effect to:</p> <p>(a) Provide the Waikato Regional Council with three (3) months written notice of the decision.</p> <p>(b) Provide a written report on the following:</p> <p>(i) Potential effects of the leachate on both the tertiary wetland and the receiving waters of Lake Waikare.</p> <p>(ii) Proposed mitigations for any adverse effects that is potentially significant.</p> <p>(c) Enact a revision to the treatment system management plan as set down under condition 7 above.</p> <p>(d) Enact a revision to the monitoring programmes as set down under conditions 18 and 21 above.</p> <p>(e) Such revision to the monitoring programme under condition 18 above shall include in addition to all other requirements:</p> <p>(i) The installation of three (3) piezometers to monitor the effects of the system on groundwater quality.</p> <p>(ii) Piezometers installed to monitor the effects of the leachate component in the treated wastewater</p>	<p>Yes</p> <p>Yes</p> <p>Yes</p>	<p>The Waikato District Council is not aware of any non-compliance with this condition of consent.</p> <p>Incorporated in manual approved by Environment Waikato.</p> <table border="1"> <thead> <tr> <th>Conductivity</th> <th>14-Jul-09</th> <th>28-Oct-09</th> <th>20-Jan-10</th> <th>20-Apr-10</th> </tr> </thead> <tbody> <tr> <td>BH 1</td> <td>649</td> <td>654</td> <td>644</td> <td>442</td> </tr> <tr> <td>BH 2</td> <td>693</td> <td>606</td> <td>683</td> <td>491</td> </tr> <tr> <td>BH3</td> <td>712</td> <td>686</td> <td>696</td> <td>483</td> </tr> <tr> <th>Chloride</th> <th>14-Jul-09</th> <th>28-Oct-09</th> <th>20-Jan-10</th> <th>20-Apr-10</th> </tr> <tr> <td>BH 1</td> <td>72</td> <td>50</td> <td>65</td> <td>68</td> </tr> <tr> <td>BH 2</td> <td>150</td> <td>160</td> <td>160</td> <td>168</td> </tr> <tr> <td>BH3</td> <td>99</td> <td>92</td> <td>93</td> <td>98</td> </tr> <tr> <th>COD</th> <th>14-Jul-09</th> <th>28-Oct-09</th> <th>20-Jan-10</th> <th>20-Apr-10</th> </tr> </tbody> </table>	Conductivity	14-Jul-09	28-Oct-09	20-Jan-10	20-Apr-10	BH 1	649	654	644	442	BH 2	693	606	683	491	BH3	712	686	696	483	Chloride	14-Jul-09	28-Oct-09	20-Jan-10	20-Apr-10	BH 1	72	50	65	68	BH 2	150	160	160	168	BH3	99	92	93	98	COD	14-Jul-09	28-Oct-09	20-Jan-10	20-Apr-10
Conductivity	14-Jul-09	28-Oct-09	20-Jan-10	20-Apr-10																																												
BH 1	649	654	644	442																																												
BH 2	693	606	683	491																																												
BH3	712	686	696	483																																												
Chloride	14-Jul-09	28-Oct-09	20-Jan-10	20-Apr-10																																												
BH 1	72	50	65	68																																												
BH 2	150	160	160	168																																												
BH3	99	92	93	98																																												
COD	14-Jul-09	28-Oct-09	20-Jan-10	20-Apr-10																																												

	Conditions	Comply Yes/No	Comments				
	<p>discharge on ground. Wetland and lake water quality shall be placed in an area likely to be representative of the effects of the discharge.</p> <p>(iii) An additional one (1) piezometer shall be installed and maintained in the vicinity of the treatment site, but in a location unlikely to be affected by the discharge.</p> <p>(iv) The consent holder shall advise the Waikato Regional Council of the number, location and depth of these piezometers, and the reasons for selecting a particular location.</p> <p>(v) Groundwater levels shall be measured in all the piezometers on a quarterly basis, in such a manner so as to ensure that the piezometer does not become contaminated prior to sampling.</p> <p>(vi) Groundwater samples shall be taken and analysed from all the piezometers for leachate contaminants on a quarterly basis for conductivity, nitrate-N, chloride, COD, ammonium-N, total zinc and total iron.</p> <p>(f) The consent holder shall make the results of all sampling undertaken available to the Waikato Regional Council at all reasonable times. And shall include under condition 23 an overview of the sampling analysis and any actual or potential effects due to any contaminants from the leachate.</p>		<p>BH 1 100 97 100 103</p> <p>BH 2 <6 11 <6 <6</p> <p>BH3 100 23 31 290</p> <p>Total Iron 14-Jul-09 28-Oct-09 20-Jan-10 20-Apr-10</p> <p>BH 1 63 72 62 62</p> <p>BH 2 26 96 24 18</p> <p>BH3 90 66 34 44</p> <p>Total Zinc 14-Jul-09 28-Oct-09 20-Jan-10 20-Apr-10</p> <p>BH 1 0.0085 0.015 0.0099 0.0036</p> <p>BH 2 0.038 0.032 0.028 0.0186</p> <p>BH3 0.095 0.011 0.012 0.26</p> <p>NH4-N 14-Jul-09 28-Oct-09 20-Jan-10 20-Apr-10</p> <p>BH 1 2.4 1.3 2.5 2.3</p> <p>BH 2 0.32 0.28 0.23 0.28</p> <p>BH3 1.9 2 1.8 1.82</p> <p>Nitrate NO3-N 14-Jul-09 28-Oct-09 20-Jan-10 20-Apr-10</p> <p>BH 1 0.012 0.015 0.017 0.056</p> <p>BH 2 0.0046 0.0094 0.047 0.056</p> <p>BH3 0.056 0.022 0.028 0.0125</p>				
18	The consent holder shall notify the Waikato Regional Council as soon as practicable and, as a minimum requirement, within 12 hours, of the consent holder becoming aware of any exceedence of the limits of this resource consent and of any accidental discharge, plant breakdown, or other circumstances which is likely to result in an exceedence of the limits of this resource consent. The consent holder shall, within seven (7) days of the incident occurring, provide a written report to the Waikato Regional Council, identifying the breach, possible causes and steps to ensure future compliance.	Yes	<p>There were no accidental discharges or major breakdowns during the 2009-2010 year.</p> <p>During heavy rainfall discharge flows exceeded the consent limit. This did not compromise treatment performance.</p>				
19	The consent holder shall keep a record of all complaints lodged	Yes	No complaints have been received from potentially affected people during the 2009-				

	Conditions	Comply Yes/No	Comments
	regarding the treatment system. The records shall include the complainants name (if this is given), the nature of the complaint, date, and time of the alleged incident and action taken by the consent holder in response to the complaint. The action shall also include steps to be taken to ensure a similar incident does not reoccur.		10 year. The Customer Delivery Team at the Waikato District Council keeps the complaint log.
20	The consent holder shall be responsible for any erosion control works that become necessary as a result of the exercise of this resource consent.	Yes	The Waikato District Council undertakes erosion control works as and when necessary to protect the integrity of the wastewater treatment system. No erosion control works were necessary during the reporting period.
21	Bare soil surfaces shall be re-vegetated at the completion of each stage of the upgrade.	Yes	
22	There shall be no visible discharge of oil or grease into or out of the wetland system.	Yes	<p>There have been no reports of any instances that may consider this condition to be breached. Fortnightly checks are done on the wastewater treatment system and any problems noted for the attention of the council's Plants Engineer.</p> <p>Periodically the primary screen receives noticeable fats and grease but no visible discharge of oil or grease from the treatment ponds or out of the wetland system has been observed.</p>
23	<p>The Waikato Regional Council may, under section 128 of the Resource Management Act, initiate a review of the conditions of this resource consent during the term of this consent for any of the following purposes:</p> <ul style="list-style-type: none"> (i) To generally review the effectiveness of the conditions of this resource consent in avoiding or mitigating any adverse effects on the environment from the operation and if considered appropriate by the Waikato Regional Council to deal with such effects by way of further or amended conditions; (ii) If necessary and appropriate, to require the holder of this resource consent to adopt the best practicable option to remove or reduce adverse effects on the surrounding environment due to contaminant discharge to Lake Waikare; and (iii) To review the adequacy of and the necessity for monitoring undertaken by the consent holder. 	Yes	<p>The only issue arising from the exercise of the resource consent during the 2009-2010 year that suggests a review of conditions under section 128 is the possible need to increase the Maximum daily discharge volume allowed.</p> <p>It may be worthwhile to review the necessity for some of the monitoring undertaken under the terms of the consent.</p>

	Conditions	Comply Yes/No	Comments
24	The consent holder shall pay to the Waikato Regional Council any administrative charge fixed in accordance with section 36 of the Resource Management Act 1991, or any charge prescribed in accordance with regulations made under section 360 of the Resource Management Act.	Yes	The Waikato District Council pays an annual fee to Environment Waikato for the reasonable cost of administration and auditing of the resource consent.
	The following conditions shall be enforced from the 1 July 2000 to the expiry of this consent.		
25	The total nitrogen-loading rate into the wetland system shall not exceed 50 kilograms per hectare per day.	Yes	<p>Compliant. Monthly data indicated that the Maximum Total Nitrogen average daily loading into the wetland was 8.04 kg/ha/day⁺⁶ during Oct 2009. This compares to 7.52 kg/ha/day⁺⁶ during Oct 2008</p> <p>Based on 26 June 2010 estimated TN 13.8 mg/L for the month, max inflow of 2167 m³ on the day and the approximate area of the wetland as 2 Ha, the peak daily total nitrogen load applied to the wetland in 2009-2010 was 14.95 kg/Ha. This was down from the peak daily value of 17.3 kg/Ha estimated for 30 June 2009 in the previous reporting period.</p> <p>The data table annual summary shows the nutrient load discharge average monthly values for Total Nitrogen and Total Phosphorous.</p> <p>Total Nitrogen applied to the Wetland The 90th Percentile value was 5.91 kg/ha/day Median value for the 2009/10 year was 2.74 kg/ha/day</p> <p>Total Nitrogen discharged to Lake Waikare The 90th Percentile value was 6.97 kg/day Median value for the 2009/10 year was 1.14 kg/day</p> <p>Total Phosphorous discharged to the Wetland The 90th Percentile value was 1.57 kg/day Median value for the 2009/10 year was 0.84 kg/day</p> <p>Total Phosphorous discharged to Lake Waikare The 90th Percentile value was 2.43 kg/day Median value for the 2009/10 year was 1.82 kg/day</p>

	Conditions	Comply Yes/No	Comments
26	The concentration of suspended solids in discharged from the wetland shall not exceed 50 grams per cubic metre for more than 10 per cent of the samples taken on an annual basis. The frequency of this monitoring shall be as detailed in the consent holders monitoring programme as required by condition 15 of this consent.	Yes	Compliant. Much the same as the previous period. The Maximum SS was 11 14 g/m3. The Median Suspended Solids result obtained from the wetland outlet during the 2007-08-2009 2010 year was 5.9 g/m3. Much the same as 6.6 g/m3 recorded in the previous period.
27	The concentration of ammoniacal nitrogen in the discharge shall not exceed 30 grams per cubic metre.	Yes	Compliant NH4-N. The Maximum value obtained was 3.74 8.1 g/m3. The Median Total Ammoniacal Nitrogen result was 0.51 grams/cubic metre. The median result was 1.3 grams/cubic metre.
28	The concentration of faecal coliforms in the discharge shall not exceed a daily median of 5,000 MPN (Most Probable Number) per 100 millilitres. The median shall be determined from five samples collected during 30 consecutive days.	Yes Minor Non-compliance	Compliant. Improved on previous period. The Maximum recorded FC for the reporting period was 400 530 MPN/100 mL, down from 1000 MPN/100 mL reported in 2008-2009. The Median was calculated from the 12 monthly samples collected over the entire reporting period. Values were substantially below consented limits for both the final effluent and also the pond effluent prior to entry to the wetland. Treatment performance quality is high. The Median FC result in the wetland discharge for the entire reporting period was 185 260 MPN/100 mL slightly up on the previous period. The 90 Percentile was 460 MPN/100 mL for the reporting period, down from 700 MPN/100 mL for 2008-2009 The Average FC result in the Pond 2 discharge for the reporting period was 185 1021 MPN/100 mL down from 2500 MPN/100 mL for 2008-2009. The overall treatment performance removal of Faecal Coliforms has improved.