

CONSENT MONITORING REPORT



Your Community Partner

Consent Name	Te Kauwhata Wastewater Treatment System
Consent No.	940355
Year	2007-08
Date	22 October 2008
File No.	55 06 19M

District Office
15 Galileo St, Private Bag 544
Ngaruawahia New Zealand
Ph 07 824 8633
Fax 07 824 8091
Call Free 0800 492 452
www.waikatodistrict.govt.nz

Area Offices
Huntly 07 828 7551
Raglan 07 825 8129

REPORT/COMMENTS

Te Kauwhata Wastewater Treatment System

The Waikato District Council holds resource consent (940355) to discharge up to 1080 cubic metres of treated wastewater per day from the Te Kauwhata wastewater treatment plant to Lake Waikare.

A review of the consent conditions during the 2007-08 reporting year indicated that the treatment system is meeting the water quality parameters of the resource consent and having no more than a minor environmental effect.

Discharge water quality parameters generally improved on the results of the previous reporting period.

The maximum consented discharge flow was exceeded for more than 40 days over July and August 2007 during a period of extremely wet weather. Data and comments provided reflect the requirements of the resource consent.

An application to renew the resource consent was made on the 30th January 2008, six months prior to expiry. The application was notified and received a number of submissions in opposition. The application is on hold while consultation continues with submitters.

.....
H Cameron
Plants Engineer

.....
R J Bax
Community Assets Group Manager